

A not-for-profit organization  
dedicated to public safety and  
committed to quality service



September 28, 2006

Custom Cooler Inc.  
Mr. Jim Conner  
11210 Inland Ave  
Mira Loma, CA 91752

Our Reference: R25285

Dear Mr. Conner:

This letter is intended to verify the UL Classification of Custom Cooler Inc.

The products, as specified in our Follow-Up Service Procedure R25285, are eligible to bear our Surface Burning Characteristics Classification Marking as shown below:

	<b>Core Material</b>	<b>3 1/2 thru 5 in. thick Painted or Unpainted Steel Finished Panel</b>
Flame spread	20	15
Smoke developed	300	250

The Classification Marking of Underwriters Laboratories Inc. on the product is the only method provided by Underwriters Laboratories Inc. to identify products that have been produced under our Follow-Up Service Program.

Please feel free to call if you have any questions.

Very truly yours,

Handwritten signature of Judith G. Marzullo in black ink.

JUDITH G. MARZULLO  
Lead Engineering Associate  
Fire Protection Division

Reviewed By:

Handwritten signature of Jams F. Smith in black ink.

JAMS F. SMITH  
Lead Engineering Associate  
Fire Protection Division